

The manufacturer
may use the marks:



Certification Report:

JCI 19-07-144 R002 V1R2 CSA 1.0.0
ISASecure Device Assessment Report
YVAA Style B

Application Restrictions:

The unit shall be operated in a network and operational environment meeting the assumptions in the product certification report.

Validity:

Product certificate remains valid under the following conditions:

- The following SDLA certificate remains valid: ISASecure® SDLA certificate number JCI 2304032 C001
- YVAA Style B Air-Cooled Screw Chiller Control Panel with Graphical User Interface V06 remains under security management practices thereby certified

Revision 1.2 May 18, 2025



ISASecure Chartered Laboratory:

exida

80 North Main St.
Sellersville, PA 18960
License: ISCI-CL0001
AClass Cert No: AT-1531



T-171 V1R6

Certificate / Certificat Zertifikat / 合格証

JCI 1907144 C005

exida hereby confirms that the

**YVAA Style B Air-Cooled Screw Chillers
Johnson Controls International PLC
Cork, Ireland**

Conforms to 62443 requirements listed and to requirements shown:

**ANSI/ISA-62443-4-1:2018, IEC 62443-4-1:2018 Secure product
development lifecycle requirements**

**ANSI/ISA-62443-4-2:2018, IEC 62443-4-2:2019 Technical
security requirements for IACS components**

Meeting Requirements for:

**ISASecure Component Security Assurance (CSA) 1.0.0
Capability Security Level 1 requirements for embedded
devices, referencing errata CSA-102 v1.9**

The normative documents and issue dates that define this certification are listed
at www.isasecure.org

Assessment	Subject under Assessment	Date	Current releases at time of assessment
ISASecure® CSA evaluation	YVAA Style B Air-Cooled Screw Chiller Control Panel with Graphical User Interface	March 28, 2024	V03, V04 & V05
ISASecure® Certificate Update		May 18, 2025	V06



Evaluating Assessor

Certifying Assessor