

The manufacturer
may use the marks:



Certification Report:

JCI 2110089 R003 V1R1

Application Restrictions:

The unit shall be operated in a network and operational environment meeting the assumptions in the product certification report.

Validity:

Product certificate remains valid under conditions:

- The following SDLA certificate remains valid: JCI 1909037 SDLA 2.0.0 Assessment Report
- YMC² ModA Centrifugal Chiller OptiView™ Control Panel V12 remains under security management practices thereby certified

Revision 1.1 May 19, 2025



ISA Secure Chartered Laboratory:

exida

80 North Main St.
Sellersville, PA 18960

License: ISCI-CL0001

ACLASS Cert No: AT-1531



T-171 V1R1

Certificate / Certificat Zertifikat / 合格証

JCI 2110089 C003

exida hereby confirms that the

YMC² ModA Centrifugal Chillers Johnson Controls International PLC Cork, Ireland

Conforms to 62443 requirements listed and to requirements shown:

**ANSI/ISA-62443-4-1:2018, IEC 62443-4-1:2018 Secure product
development lifecycle requirements**

**ANSI/ISA-62443-4-2:2018, IEC 62443-4-2:2018 Technical
security requirements for IACS components**

Meeting Requirements for:

**ISA Secure Component Security Assurance (CSA) 1.0.0
Capability Security Level 1 requirements for embedded
devices, referencing errata CSA-102 v1.9**

The normative documents and issue dates that define this certification are listed
at www.isasecure.org

Assessment	Subject under Assessment	Date	Current release at time of assessment
ISA Secure® CSA evaluation	YMC ² ModA Centrifugal Chiller OptiView™ Control Panel	July 27, 2022	V10
ISA Secure® certificate update		May 19, 2025	V11 & V12



Bill Thonson, *Shane Cum*

Evaluating Assessor

David A. Johnson

Certifying Assessor